



MARTIN COUNTY FIRE RESCUE

Fire Prevention
800 SE Monterey Road
Stuart, FL 34994
772 288-5633

Fire_prevention@martin.fl.us



FIRE ALARM FINAL INSPECTION Check List

Applicable Base Codes

All work shall be completed in accordance with the latest adopted edition of the Florida Fire Prevention code and referenced publications within.

This document is intended to be a guide and may not contain all requirements needed to obtain permits and approval from Martin County Fire Rescue/Fire Prevention.

Fire Alarm System (NFPA 72)

- Confirm shop drawings are approved
- Verify:
 - Verify panel is online and clear
 - Call dispatch with your location and status
 - For new flow switches and tamper switches, verify operation
 - Verify that dispatch has received an alarm signal
 - Place the alarm system in "Test Mode" to prevent further signals to dispatch
 - Conduct fire alarm operations test

This document may be reproduced upon request in an alternative format by contacting the County ADA Coordinator (772) 320-3131, the County Administration Office (772) 288-5400, Florida Relay 711, or by completing our accessibility feedback form at www.martin.fl.us/accessibility-feedback.