



# MARTIN COUNTY FIRE RESCUE

Fire Prevention  
800 SE Monterey Road  
Stuart, FL 34994  
772 288-5633  
Fire\_prev@martin.fl.us



## FIRE SPRINKLER FINAL INSPECTION Check List

### Applicable Base Codes

All work shall be completed in accordance with the latest adopted edition of the Florida Fire Prevention code and referenced publications within.

**This document is intended to be a guide and may not contain all requirements needed to obtain permits and approval from Martin County Fire Rescue/Fire Prevention.**

### **Sprinkler System (NFPA 13)**

- Confirm shop drawings are approved  
Verify:
- Sprinkler system fire permit is cleared
- Sprinklers are installed properly as shown on approved plans
- All escutcheon plates are installed properly
- Hydraulic nameplates are installed on each riser

This document may be reproduced upon request in an alternative format by contacting the County ADA Coordinator (772) 320-3131, the County Administration Office (772) 288-5400, Florida Relay 711, or by completing our accessibility feedback form at [www.martin.fl.us/accessibility-feedback](http://www.martin.fl.us/accessibility-feedback).