



# MARTIN COUNTY FIRE RESCUE

Fire Prevention  
800 SE Monterey Road  
Stuart, FL 34994  
772 288-5633  
Fire\_prev@martin.fl.us



## FIRE SPRINKLER FINAL INSPECTION Check List

### Applicable Base Codes

Florida Fire Prevention Code, 7th Edition  
NFPA 1, Uniform Fire Code, Florida 2018 Edition  
NFPA 101, Life Safety Code, Florida 2018 Edition  
NFPA 13, 2017 edition  
NFPA 72, 2016 edition

**This document is intended to be a guide and may not contain all requirements needed to obtain permits and approval from Martin County Fire Rescue/Fire Prevention.**

### **Sprinkler System (NFPA 13)**

- ☐ Confirm shop drawings are approved  
Verify:
- ☐ Sprinkler system fire permit is cleared
- ☐ Sprinklers are installed properly as shown on approved plans
- ☐ All escutcheon plates are installed properly
- ☐ Hydraulic nameplates are installed on each riser

This document may be reproduced upon request in an alternative format by contacting the County ADA Coordinator (772) 320-3131, the County Administration Office (772) 288-5400, Florida Relay 711, or by completing our accessibility feedback form at [www.martin.fl.us/accessibility-feedback](http://www.martin.fl.us/accessibility-feedback).